

Code Amendment Proposal Form

For public amendments proposed to the 2021 editions of the International Codes



Instructions: Upload this form and all accompanying documentation. If you are submitting your proposal on a separate sheet, make sure it includes all information requested below.

All proposals must be received by **July 23, 2021**.

CONTACT INFORMATION

Name: John McGovern

Date: July 21, 2021

Phone: 720-320-4884

E-mail: macjm@aol.com

Organization or Representing Self: Self

By signing below, I hereby grant and assign to City and County of Denver all rights in copyright I may have in any authorship contributions I make to City and County of Denver in connection with this proposal. I understand that I will have no rights in any City and County of Denver publications that use such contributions in the form submitted by me or another similar form and certify that such contributions are not protected by the copyright of any other person or entity.

Signature:

AMENDMENT PROPOSAL

Please use a separate form for each proposal.

1) Code(s) associated with this proposal. Please use acronym: IFC

If you submitted a separate coordination change to another code, please indicate which code: _____

<u>Acronym</u>	<u>Code Name</u>	<u>Acronym</u>	<u>Code Name</u>
DBC-AP	Denver Building Code—Administrative Provisions	IFC	International Fire Code
DBC-xxxx	Denver Building Code—xxxx (code) amendments (e.g., DBC-IBC, DBC-IEBC)	IFGC	International Fuel Gas Code
IBC	International Building Code	IRC	International Residential Code
IEBC	International Existing Building Code	IMC	International Mechanical Code
IECC	International Energy Conservation Code	IPC	International Plumbing Code
		DGC	Denver Green Code

2) Please check here if a separate graphic file is provided:

Graphics may also be embedded within your proposal below.

3) Use this template to submit your proposal or attach a separate file, but please include all items requested below in your proposal. The only formatting needed is **BOLDING, STRIKEOUT AND UNDERLINING**. Please do not provide additional formatting such as tabs, columns, etc., as this will be done by CPD.

Code Sections/Tables/Figures Proposed for Revision:

Section 907.6.4.10 Duct detectors (supervisory only). Maximum of 20 devices per zone.

Note: If the proposal is for a new section, indicate (new).

Proposal:

Delete the following text and add the new text as follows.

Section 907.6.4, item 10, Duct detectors (~~supervisory only~~ except for duct detectors required for activation of smoke control systems activation as required by Section 907.2.13.5 shall be supervisory alarms). Maximum of 20 devices per zone.

Supporting Information:

The two sections conflict and the duct detectors in the return air ducts of high rises are often not included in the Sequence of Operation to active the smoke control system.

Referenced Standards:

Note: List any new referenced standards that are proposed to be referenced in the code.

Impact:

Simply a change in programming.

Note: Discuss the impact of this proposal in this section AND indicate the impact of this amendment proposal for each of the following:

- The effect of the proposal on the cost of construction: Increase Reduce No Effect
- The effect of the proposal on the cost of design: Increase Reduce No Effect
- Is the proposal more or less restrictive than the I-codes: More Less Same

Departmental Impact: (To be filled out by CPD staff)

Note: CITY STAFF ONLY. Discuss the impact of this proposal in this section AND indicate the impact of this amendment proposal for each of the following:

- The effect of the proposal on the cost of review: Increase Reduce No Effect
- The effect of the proposal on the cost of enforcement/inspection: Increase Reduce No Effect