



- Reason: Why is your proposal necessary?

First, it ensures that the annunciator is at the proper location for gas detection systems. It also annunciates gas events at the fire alarm control panel. Finally, some minor grammatical edits were provided.

- Substantiation: Why is your proposal valid? (i.e. technical justification)

There may be no emergency alarm system in a building with a gas detection system; these are separate entities. This proposal also ensures that first responders can gather information about the gas event at the FACP, which is sited by DFD, rather than having to go to the gas detection system panel.

**Bibliography and Access to Materials** (as needed when substantiating material is associated with the amendment proposal):

**Other Regulations Proposed to be Affected**

**\*For proposals to delete content from the 2019 Denver Green Code in conjunction with adding it to other mandatory Denver codes and/or regulations, only.**

Please identify which other mandatory codes or regulations are suggested to be updated (if any) to accept relocated content.

**Referenced Standards:**

List any new referenced standards that are proposed to be referenced in the code.

**Impact:**

How will this proposal impact cost and restrictiveness of code? ("X" answer for each item below)

Cost of construction:	<input type="checkbox"/> Increase	<input type="checkbox"/> Decrease	<input checked="" type="checkbox"/> No Impact
Cost of design:	<input type="checkbox"/> Increase	<input type="checkbox"/> Decrease	<input checked="" type="checkbox"/> No Impact
Restrictiveness:	<input type="checkbox"/> Increase	<input type="checkbox"/> Decrease	<input checked="" type="checkbox"/> No Impact

**Departmental Impact (City use only):**

This amendment proposal increases/decreases/is neutral to the cost of plans review.

This amendment increases/decreases/is neutral to the cost of inspections.