

# Code Amendment Proposal Form

For public amendments proposed to the 2021 editions of the International Codes



**Instructions:** Upload this form and all accompanying documentation. If you are submitting your proposal on a separate sheet, make sure it includes all information requested below.

All proposals must be received by **July 23, 2021**.

## CONTACT INFORMATION

**Name:** Mike Stewart

**Date:** 7/1 21

**Phone:** 720.913.4183

**E-mail:** Michael.stewart@denvergov.org

**Organization or Representing Self:**

*By signing below, I hereby grant and assign to City and County of Denver all rights in copyright I may have in any authorship contributions I make to City and County of Denver in connection with this proposal. I understand that I will have no rights in any City and County of Denver publications that use such contributions in the form submitted by me or another similar form and certify that such contributions are not protected by the copyright of any other person or entity.*

**Signature:**

## AMENDMENT PROPOSAL

**Please use a separate form for each proposal.**

1) Code(s) associated with this proposal. Please use acronym: NFPA 13

If you submitted a separate coordination change to another code, please indicate which code: \_\_\_\_\_

<u>Acronym</u>	<u>Code Name</u>	<u>Acronym</u>	<u>Code Name</u>
DBC-AP	Denver Building Code—Administrative Provisions	IFC	International Fire Code
DBC-xxxx	Denver Building Code—xxxx (code) amendments (e.g., DBC-IBC, DBC-IEBC)	IFGC	International Fuel Gas Code
IBC	International Building Code	IRC	International Residential Code
IEBC	International Existing Building Code	IMC	International Mechanical Code
IECC	International Energy Conservation Code	IPC	International Plumbing Code
		DGC	Denver Green Code

2) Please check here if a separate graphic file is provided:   
*Graphics may also be embedded within your proposal below.*

3) Use this template to submit your proposal or attach a separate file, but please include all items requested below in your proposal. The only formatting needed is **BOLDING**, ~~STRIKEOUT~~ AND UNDERLINING. Please do not provide additional formatting such as tabs, columns, etc., as this will be done by CPD.

### Code Sections/Tables/Figures Proposed for Revision:

Denver Fire Code, Section 920.24 - New

### Section 920.24 Fire-rated suspension and controller replacements is added as follows

920.24 Fire-rated suspension and controller replacements. New elevator installations and alterations utilizing noncircular elastomeric-coated or polyurethane-coated steel belts shall be fire-rated. Existing elevators utilizing coated steel belts, at time of suspension means or controller replacement, shall be installed with the fire-rated type. The fire rating shall not be less than an FT-1 rating when tested to the vertical burn test requirements of UL 2556, Wire and Cable Test Methods, where the suspension means shall not continue to burn for more than 60 seconds, nor shall the indicator flag be burned more than 25 percent.

### Supporting Information:

